

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95% [%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
04.09.2023/10 ⁵⁰	Zona Judeteana-ZAP Merei Rez. Prag	Nitriti	mg/l	<0,005 (LQ)	±10 %	0,100	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	7,113	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	978 (20,6 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	101,594	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,20	±10 %	≥0,10; ≤0,50	SR EN ISO 7393-1:2002
		Duritate totala	°G	19,41	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,53 (20,3 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,61	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002		

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
04.09.2023/11 ¹⁵	Zona Judeteana-ZAP Cozieni Rez. statie tratare	Nitriti	mg/l	0,008	±10 %	0,100	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	1,966	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1612 (20,6 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,51	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	0,095	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	153,097	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,34	±10 %	≥0,10; ≤0,50	SR EN ISO 7393-1:2002
		Duritate totala	°G	19,64	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,69 (20,7 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,76	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier (mg/l)	mg/l	<0,06 (LQ)	± 20%	0,200	SR 13315:1996 SR 13315:1996/C91:2008
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	2	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017		
Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002		

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95% [%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
04.09.2023/10 ²⁰	Zona Judeteana-ZAP Zoresti Rez. Zoresti	Nitriti	mg/l	<0,005 (LQ)	±10 %	0,100	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	2,007	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	983 (20,3 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	166,502	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,39	±10 %	≥0,10; ≤0,50	SR EN ISO 7393-1:2002
		Duritate totala	°G	16,05	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,64 (20,5 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	1,40	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95% [%]	VAL. ADMISA conf. Ordonantei nr. 7/18.01.2023	METODA DE INCERCARE
05.09.2023/08 ⁰⁰	Zona Metropolitana-ZAP Buzau Rez. iesire statie tratare Sursa Zahar	Nitriti	mg/l	<0,005 (LQ)	±10 %	0,100	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	15,652	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1468 (20,0 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	248,341	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,38	±10 %	≥0,10; ≤0,50	SR EN ISO 7393-1:2002
		Duritate totala	°G	20,53	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,95 (20,8 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	1,00	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier (mg/l)	mg/l	<0,06 (LQ)	± 20%	0,200	SR 13315:1996 SR 13315:1996/C91:2008
		Mangan (mg/l)	mg/l	<0,015 (LQ)	± 20%	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	2	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017		
Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002		

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95% [%]	VAL. ADMISA conf. Ordonantei nr. 7/18.01.2023	METODA DE INCERCARE
05.09.2023/09 ⁰⁰	Zona Metropolitana-ZAP Buzau Rez. iesire statie Sursa Crang	Nitriti	mg/l	<0,005 (LQ)	±10 %	0,100	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	19,142	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1093 (19,8 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,90	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	189,078	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,39	±10 %	≥0,10; ≤0,50	SR EN ISO 7393-1:2002
		Duritate totala	°G	17,39	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,57 (19,9 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,43	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	3	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002		

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/18.01.2023	METODA DE INCERCARE
05.09.2023/09 ³⁵	Zona Metropolitana-ZAP Buzau Rez. iesire statie tratare Sursa Sud	Nitriti	mg/l	<0,005 (LQ)	±10 %	0,100	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	14,915	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	868 (19,6 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	125,582	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,36	±10 %	≥0,10; ≤0,50	SR EN ISO 7393-1:2002
		Duritate totala	°G	14,03	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,93 (19,6 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,39	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier (mg/l)	mg/l	<0,060 (LQ)	± 20%	0,200	SR 13315:1996 SR 13315:1996/C91:2008
		Mangan (mg/l)	mg/l	<0,015 (LQ)	± 20%	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002		

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
05.09.2023/10 ¹⁰	Zona Judeteana-ZAP Rm. Sarat Rez. Voetin	Nitriti	mg/l	<0,005 (LQ)	±10 %	0,100	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	19,477	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1253 (20,7 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	160,857	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,51	±10 %	≥0,10; ≤0,50	SR EN ISO 7393-1:2002
		Duritate totala	°G	21,54	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,37 (20,6 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,50	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017		
<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017		
Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002		

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
06.09.2023/10 ⁰⁰	Zona Judeteana-ZAP Grebanu Rez. Livada Mare	Nitriti	mg/l	<0,005 (LQ)	±10 %	0,100	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	34,495	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	703 (20,4 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	14,463	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,47	±10 %	≥0,10; ≤0,50	SR EN ISO 7393-1:2002
		Duritate totala	°G	21,99	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,82 (20,6 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	2,10	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	10	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	5	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002		

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
20.09.2023/09 ⁴⁵	Zona Judeteana-ZAP Pogoanele Rez. statie tratare	Nitriti	mg/l	<0,005 (LQ)	±10 %	0,100	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	0,400	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1177 (20,5 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	230,445	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,44	±10 %	≥0,10; ≤0,50	SR EN ISO 7393-1:2002
		Duritate totala	°G	19,41	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,74 (20,4 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	1,10	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier (mg/l)	mg/l	0,07	± 20%	0,200	SR 13315:1996 SR 13315:1996/C91:2008
		Mangan (mg/l)	mg/l	0,018	± 20%	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	3	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017		

		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002
--	--	---	--------------------	---	---	---	-----------------------

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
26.09.2023/11 ³⁰	Zona Judeteana-ZAP Calvini Rez. Iorgulesti	Nitriti	mg/l	<0,005 (LQ)	±10 %	0,100	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	15,278	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1058 (20,2 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,51	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	103,005	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,28	±10 %	≥0,10; ≤0,50	SR EN ISO 7393-1:2002
		Duritate totala	°G	27,88	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,40 (19,6 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,46	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	4	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017		
Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002		

ATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/18.01.2023	METODA DE INCERCARE
28.09.2023/08 ⁴⁵	Zona Metropolitana-ZAP Buzau Rez. iesire statie tratare Sursa Zahar	Nitriti	mg/l	<0,005 (LQ)	±10 %	0,100	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	11,887	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1181 (20,5 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,58	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	212,713	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,45	±10 %	≥0,10; ≤0,50	SR EN ISO 7393-1:2002
		Duritate totala	°G	16,00	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,99 (20,5 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,30	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier (mg/l)	mg/l	<0,06 (LQ)	± 20%	0,200	SR 13315:1996 SR 13315:1996/C91:2008
		Mangan (mg/l)	mg/l	<0,015 (LQ)	± 20%	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	2	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017		

		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002
--	--	---	--------------------	---	---	---	-----------------------

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/18.01.2023	METODA DE INCERCARE
28.09.2023/09 ³⁵	Zona Metropolitana-ZAP Buzau Rez. iesire statie Sursa Crang	Nitriti	mg/l	<0,005 (LQ)	±10 %	0,100	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	14,618	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1075 (20,3 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,54	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	195,428	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,44	±10 %	≥0,10; ≤0,50	SR EN ISO 7393-1:2002
		Duritate totala	°G	17,55	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,69 (20,4 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	1,10	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	4	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	2	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002		

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/18.01.2023	METODA DE INCERCARE
28.09.2023/07 ⁵⁵	Zona Metropolitana-ZAP Buzau Rez. iesire statie tratare Sursa Sud	Nitriti	mg/l	<0,005 (LQ)	±10 %	0,100	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	3,480	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	867 (20,1 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,70	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	143,925	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,32	±10 %	≥0,10; ≤0,50	SR EN ISO 7393-1:2002
		Duritate totala	°G	12,08	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	8,03 (20,4 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,34	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier (mg/l)	mg/l	<0,060 (LQ)	± 20%	0,200	SR 13315:1996 SR 13315:1996/C91:2008
		Mangan (mg/l)	mg/l	<0,015 (LQ)	± 20%	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	2	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017		
<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017		

		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002
--	--	---	--------------------	---	---	---	-----------------------