

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
07.07.2025/08 ³⁰	Zona Metropolitana- ZAP Buzau Consumator Sursa Sud	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	34,984	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	μS/cm	1325 (19,1 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,58	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	226,899	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,36	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	21,54	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,41 (20,4 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,46	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,060 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015 (LQ)	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	32	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	17	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
07.07.2025/10 ⁰⁵	Zona Metropolitana- ZAP Buzau Consumator Sursa Zahar	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	23,262	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	μS/cm	1245 (19,0 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	204,918	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,39	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	17,78	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,84 (20,7 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,24	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,060 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015 (LQ)	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	2	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
7.07.2025/08 ⁴⁵	Zona Metropolitana- ZAP Buzau Consumator Sursa Crang	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	36,056	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	μS/cm	1338 (19,1 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,65	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	233,281	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,16	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	21,43	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,40 (20,8 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,22	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	5	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	2	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
07.07.2025/09 ⁰⁰	Zona Judeteana- ZAP Murgesti Consumator Valea Ratei	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	0,874	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	μS/cm	1998 (20,7 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,90	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	47,862	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,14	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	8,19	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,93 (20,6 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	2,20	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
09.07.2025/09 ⁴⁵	Zona Judeteana- ZAP Viperesti Consumator Tronari	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	2,485	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	μS/cm	878 (20,4 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	85,796	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,34	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	17,95	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,68 (20,6 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,81	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	3	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	2	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
09.07.2025/10 ²⁰	Zona Judeteana- ZAP Cislau Consumator Cislau	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	2,742	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	992 (20,8 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	108,486	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,39	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	19,69	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,74 (20,5 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	2,20	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	78	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	36	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
10.07.2025/10 ³⁵	Zona Judeteana- ZAP Merei Consumator Ulmeni	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	6,540	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	917 (20,4 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	131,885	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,45	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	15,82	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,66 (20,4 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,33	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
15.07.2025/11 ²⁵	Zona Metropolitana- ZAP Buzau Consumator Sursa Zahar	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	12,506	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	μS/cm	1129 (20,2 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	197,828	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,20	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	15,88	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,90 (20,8 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,30	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,060 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015 (LQ)	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	5	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	3	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
17.07.2025/12 ¹⁰	Zona Judeteana- ZAP Rm. Sarat Consumator Sursa Voetin	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	20,309	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1419 (19,0 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	218,391	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,20	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	22,44	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,35 (19,1 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,42	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	16	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	7	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

