

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
1.09.2025/13 ²⁵	Zona Judeteana- ZAP Patarlagele Consumator sursa Zagastru	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	1,989	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	428 (20,1 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	2,50	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	53,619	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,30	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	8,49	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,70 (19,0 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,98	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	3	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002
		<i>Clostridium perfringens</i>	nr. UFC /100 ml	0	-	0	SR EN ISO 14189:2017

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
1.09.2025/10 ³⁰	Zona Judeteana- ZAP Patarlagele Consumator Sursa Poieni dren	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	4,533	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	927 (19,6 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,77	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	100,889	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,24	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	19,37	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,68 (19,3 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,37	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	3	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMIMATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
1.09.2025/10 ⁰⁰	Zona Judeteana- ZAP Patarlagele Consumator Sursa Poieni izvoare	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	4,370	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	940 (19,4 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	1,86	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	103,358	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,26	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	19,03	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,79 (19,0 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,61	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMIMATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
1.09.2025/12 ⁵⁰	Zona Judeteana- ZAP Patarlagele Consumator Sursa Maruntisu	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	5,640	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	816 (20,4 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	99,125	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,16	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	19,82	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,80 (19,0 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,74	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMIMATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
1.09.2025/10 ²⁰	Zona Judeteana- ZAP Murgesti Consumator sursa Batogu	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	0,344	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1399 (20,8 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,77	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	26,104	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,50	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	2,15	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	8,16 (20,1 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,58	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	10	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	6	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
1.09.2025/12 ⁴⁵	Zona Judeteana- ZAP Rm. Sarat Consumator Sursa Voetin	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	21,401	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	μS/cm	1375 (20,8 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,96	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	195,428	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,10	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	23,89	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,48 (20,3 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	1,30	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	42	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	26	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
2.09.2025/13 ⁵⁰	Zona Metropolitana- ZAP Lipia Consumator Lipia	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	10,330	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	μS/cm	932 (20,1 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,58	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	142,161	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,40	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	16,24	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,74 (20,5 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,51	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	2	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
8.09.2025/11 ¹⁵	Zona Judeteana- ZAP Cislau Consumator Cislau	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	5,132	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	μS/cm	815 (20,7 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,97	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	77,610	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,24	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	18,05	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,75 (20,7 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,82	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	15	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	7	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
9.09.2025/12 ⁰⁰	Zona Judeteana- ZAP Nehoiu Consumator sat Casoca	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	2,379	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	253 (19,2 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	3,01	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	13,405	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,32	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	6,55	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,78 (20,6 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	2,30	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	3	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002
		<i>Clostridium perfringens</i>	nr. UFC /100 ml	0	-	0	SR EN ISO 14189:2017

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
09.09.2025/14 ⁰⁰	Zona Metropolitana- ZAP Buzau Consumator sursa Sud	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	23,083	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1208 (20,6 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,70	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	220,826	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,40	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	18,94	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,47 (20,3 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,30	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015 (LQ)	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
09.09.2025/14 ¹⁵	Zona Metropolitana- ZAP Buzau Consumator Sursa Crang	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	26,875	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	μS/cm	1222 (19,6 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,90	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	220,121	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,42	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	18,94	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,51 (19,8 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,54	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	14	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	8	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
15.09.2025/11 ⁵⁰	Zona Metropolitana- ZAP Buzau Consumator Sursa Zahar	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	24,862	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1173 (19,3 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,52	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	202,483	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,30	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	19,47	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,49 (20,2 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,22	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,060 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015 (LQ)	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	5	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	2	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

