

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
3.11.2025/09 ²⁰	Zona Judeteana- ZAP Grebanu Consumator sursa Livada Mica	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	7,282	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	μS/cm	578 (19,3 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,54	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	11,288	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,48	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	16,99	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,82 (20,3 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,45	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	2	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
3.11.2025/10 ⁴⁵	Zona Judeteana- ZAP Grebanu Consumator sursa Zaplazi	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	41,184	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	830 (19,4 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	19,049	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,46	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	22,45	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,89 (19,9 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,46	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	64	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	22	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
3.11.2025/09 ⁴⁰	Zona Judeteana- ZAP Grebanu Consumator sursa Livada Mare	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	42,116	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	709 (19,0 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	17,285	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,42	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	20,88	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,76 (19,4 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,54	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
3.11.2025/11 ³⁰	Zona Judeteana- ZAP Grebanu Consumator sursa Plevna 1	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	0,287	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	770 (19,6 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,61	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	16,580	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,24	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	15,02	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,67 (19,9 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,30	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015 (LQ)	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
3.11.2025/10 ²⁰	Zona Judeteana- ZAP Grebanu Consumator sursa Grebanu 1	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	40,146	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	755 (19,1 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	21,165	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,30	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	20,93	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,38 (19,5 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,53	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARI	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
3.11.2025/10 ⁰⁰	Zona Judeteana- ZAP Grebanu Consumator sursa Grebanu 2	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	43,743	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	755 (19,3 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	21,518	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,28	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	20,59	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,62 (19,7 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,82	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
4.11.2025/10 ¹⁰	Zona Judeteana- ZAP Merei Consumator sursa Nenciulesti	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	19,046	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	748 (19,1 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	24,693	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,26	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	24,08	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,53 (20,2 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,53	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	12	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	5	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
4.11.2025/09 ⁴⁰	Zona Judeteana- ZAP Merei Consumator sursa Valea Botei	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	21,336	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	957 (19,5 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	61,743	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,46	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	25,88	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,33 (19,9 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,62	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
4.11.2025/09 ⁰⁰	Zona Judeteana- ZAP Pogoanele Consumator Pogoanele	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	0,181	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1059 (20,4 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,70	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	213,771	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,38	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	18,12	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,42 (20,6 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,33	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015 (LQ)	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	16	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	7	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
4.11.2025/09 ⁵⁰	Zona Judeteana- ZAP Padina Consumator Padina	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	0,219	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1334 (20,1 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,96	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	115,704	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,28	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	26,67	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,73 (20,8 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,97	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	0,028	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
4.11.2025/11 ⁴⁵	Zona Metropolitana- ZAP Buzau Consumator Sursa Zahar	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	12,344	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1131 (19,2 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	204,599	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,44	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	16,21	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,31 (20,4 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,21	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015 (LQ)	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	6	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	3	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
4.11.2025/13 ⁴⁰	Zona Metropolitana- ZAP Buzau Consumator Sursa Crang	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	34,398	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1272 (19,5 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	237,053	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,36	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	20,54	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,91 (19,3 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,35	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	11	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	5	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
5.11.2025/11 ⁵⁰	Zona Judeteana- ZAP Rm. Sarat Consumator sursa Voetin	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	21,202	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1283 (19,7 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,77	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	166,149	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,30	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	22,51	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,45 (20,5 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	1,30	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	3	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
5.11.2025/09 ¹⁰	Zona Judeteana- ZAP V. Ramnicului Consumator V. Ramnicului	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	29,467	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	779 (20,2 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,58	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	30,690	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,36	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	18,06	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,79 (20,5 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	1,50	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015 (LQ)	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	2	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARI	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
10.11.2025/09 ²⁰	Zona Judeteana- ZAP Valea Salciei Consumator Valea Salciei	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	5,501	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	2350 (19,3 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	1,16	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	38,959	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,38	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	8,55	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	8,19 (20,2 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	1,90	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	28	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	15	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
12.11.2025/12 ⁰⁰	Zona Metropolitana- ZAP Buzau Consumator Sursa Crang	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	25,781	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1230 (19,0 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,58	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	215,505	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,30	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	19,81	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,53 (19,3 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,41	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	14	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	7	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
12.11.2025/11 ⁴⁰	Zona Metropolitana- ZAP Buzau Consumator Sursa Sud	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	21,909	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1223 (19,1 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	214,803	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,28	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	19,92	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,49 (19,5 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	1,60	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	0,019	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	18	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	10	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
17.11.2025/10 ⁰⁵	Zona Metropolitana- ZAP Buzau Consumator Sursa Est	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	32,617	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1234 (19,7 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,84	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	221,120	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,27	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	19,88	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,58 (20,1 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,17	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015 (LQ)	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	8	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	3	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
17.11.2025/09 ³⁰	Zona Metropolitana- ZAP Buzau Consumator Sursa Crang	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	22,008	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1205 (19,1 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,71	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	215,505	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,30	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	19,44	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,58 (20,0 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,35	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	6	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	3	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
17.11.2025/10 ⁴⁰	Zona Judeteana- ZAP Rm. Sarat Consumator sursa Voetin	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	18,551	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1237 (19,6 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,77	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	150,222	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,12	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	21,99	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,59 (20,7 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,53	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	28	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	12	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
24.11.2025/10 ⁴⁵	Zona Metropolitana- ZAP Buzau Consumator Sursa Crang	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	33,772	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1297 (20,5 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	223,226	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,36	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	20,72	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,39 (19,2 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,80	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	11	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	3	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
24.11.2025/11 ¹⁵	Zona Metropolitana- ZAP Buzau Consumator Sursa Zahar	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	35,722	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1332 (20,5 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	228,842	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,28	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	21,17	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,45 (19,3 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,30	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	0,025	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	13	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	7	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

