

DATA SI ORA PRELEVARII	Sector/Centru- ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
14.01.2026/11 ⁰⁰	Zona Metropolitana- ZAP Buzau Consumator Sursa Zahar	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	10,905	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1130 (19,3 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,58	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	204,273	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,34	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	15,77	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,85 (19,9 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,20	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015 (LQ)	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	9	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru- ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
14.01.2026/09 ³⁰	Zona Metropolitana- ZAP Buzau Consumator Sursa Crang	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	31,503	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1223 (19,2 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	221,120	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,49	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	19,72	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,50 (20,4 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,34	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	11	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	3	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru- ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
14.01.2026/10 ⁴⁰	Zona Judeteana- ZAP Rm. Sarat Consumator Rm. Sarat	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	19,991	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1250 (20,3 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	152,678	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,28	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	22,44	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,32 (20,8 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,25	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	3	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	3	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
14.01.2026/08 ⁵⁰	Zona Judeteana- ZAP V. Ramnicului Consumator V. Ramnicului	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	21,875	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	775 (20,0 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,77	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	29,132	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,47	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	18,55	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,81 (20,4 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,96	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	0,031	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	2	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru- ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
19.01.2026/09 ⁰⁰	Zona Judeteana- ZAP Zoresti Consumator Zoresti	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	1,954	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	986 (20,1 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	163,084	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,43	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	15,76	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,61 (20,2 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,23	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
20.01.2026/11 ¹⁵	Zona Judeteana- ZAP Grebanu Consumator Sursa Plevna 1	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	0,253	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	μS/cm	782 (19,7 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	16,486	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,50	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	16,99	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,87 (19,4 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	1,40	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015 (LQ)	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
20.01.2026/12 ⁰⁰	Zona Judeteana- ZAP Murgesti Consumator Sursa Batogu	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	0,477	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	μS/cm	1474 (20,0 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	31,553	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,44	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	2,36	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	8,32 (19,2 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	1,50	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015 (LQ)	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	4	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
20.01.2026/11 ²⁵	Zona Judeteana- ZAP Chiojdu Consumator Chiojdu	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	0,763	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	476 (19,8 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,93	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	<5,000 (LM)	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,32	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	13,45	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	8,15 (20,1 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,85	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015 (LQ)	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	2	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002
		<i>Clostridium perfringens</i>	nr. UFC /100 ml	0	-	0	SR EN ISO 14189:2017

DATA SI ORA PRELEVARII	Sector/Centru- ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
21.01.2026/10 ⁵⁵	Zona Metropolitana- ZAP Buzau Consumator Sursa Sud	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	7,655	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	865 (19,1 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	141,812	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,26	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	12,44	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	8,01 (19,4 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,53	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015 (LQ)	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	12	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	4	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru- ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
21.01.2026/10 ²⁵	Zona Metropolitana- ZAP Buzau Consumator Sursa Crang	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	25,558	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	μS/cm	1280 (19,5 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	240,371	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,28	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	20,43	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,48 (19,6 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,25	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	3	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	3	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru- ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
28.01.2026/10 ²⁵	Zona Judeteana- ZAP Rm. Sarat Consumator Rm. Sarat	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	18,360	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1444 (19,6 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	225,765	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,10	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	24,44	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,40 (19,5 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,16	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	5	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

