

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
03.02.2026/09 ⁵⁰	Zona Judeteană- ZAP Nehoiu Consumator Nehoiu	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	3,173	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	μS/cm	317 (20,0 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	1,59	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	16,932	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,40	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	8,42	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,98 (20,2 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	1,30	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002
		<i>Clostridium perfringens</i>	nr. UFC /100 ml	0	-	0	SR EN ISO 14189:2017

DATA SI ORA PRELEVARII	Sector/Centru- ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
09.02.2026/10 ⁰⁰	Zona Metropolitana- ZAP Buzau Consumator Sursa Zahar	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	9,180	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1164 (20,5 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	204,975	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,48	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	15,43	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,96 (20,2 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,23	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015 (LQ)	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	7	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru- ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
09.02.2026/09 ²⁰	Zona Metropolitana- ZAP Buzau Consumator Sursa Crang	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	26,286	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1304 (19,2 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,58	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	240,074	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,22	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	20,42	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,52 (19,3 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,61	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	2	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru- ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
09.02.2026/11 ²⁰	Zona Metropolitana- ZAP Buzau Consumator Sursa Sud	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	5,466	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	μS/cm	902 (19,3 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,78	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	147,063	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,32	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	12,12	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	8,05 (19,7 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,43	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015 (LQ)	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	5	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	2	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru- ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
09.02.2026/10 ⁴⁰	Zona Metropolitana- ZAP Buzau Consumator Sursa Est	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	6,492	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1061 (20,0 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	222,524	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,20	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	13,63	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,81 (20,0 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,18	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015 (LQ)	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	18	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	10	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru- ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
09.02.2026/08 ³⁰	Zona Judeteana- ZAP Zoresti Consumator Zoresti	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	2,009	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	991 (19,2 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,52	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	162,155	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,48	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	15,60	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,71 (19,3 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,38	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	2	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
10.02.2026/11 ⁰⁰	Zona Judeteana- ZAP Patarlagele Consumator Poieni dren	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	3,585	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	μS/cm	684 (20,0 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	43,522	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,42	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	15,48	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,85 (20,3 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,82	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru- ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
10.02.2026/10 ²⁰	Zona Judeteana- ZAP Patarlagele Consumator Poieni izvoare	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	2,988	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	674 (20,1 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	40,012	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,40	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	15,93	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,86 (20,3 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	1,10	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	0	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
11.02.2026/11 ¹⁰	Zona Judeteana- ZAP Rm. Sarat Consumator Sursa Voetin	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	17,483	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	μS/cm	1252 (19,5 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	0,58	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	155,837	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,30	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	22,10	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,38 (20,3 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,30	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	1	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru-ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
23.02.2026/08 ⁴⁰	Zona Metropolitana- ZAP Vernesti Consumator Vernesti	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	2,929	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	μS/cm	996 (19,5 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	199,359	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,41	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	15,31	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,73 (19,3 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,36	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	7	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	2	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru- ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95%[%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
25.02.2026/10 ²⁵	Zona Metropolitana- ZAP Buzau Consumator Sursa Zahar	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	8,306	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1155 (19,8 °C)	±5 %	2500	SR EN 27888:1997
		Oxidabilitate/indice de permanganat	mgO ₂ /l	<0,50 (LM)	±10 %	5,00	SR EN ISO 8467:2001
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Cloruri	mg/l	207,081	±10 %	250,000	SR ISO 9297:2001
		Clor rezidual liber	mg/l	0,32	±10 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		Duritate totala	°G	15,19	±6 %	≥ 5,00	SR ISO 6059:2008
		pH	unit. pH	7,92 (19,4 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,39	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier	mg/l	<0,06 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Mangan	mg/l	<0,015 (LQ)	±20 %	0,050	SR 8662-2:1996
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012-Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	12	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	4	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308-1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002